



---

450 W. Business Park Road ● Shelton, WA 98584  
Phone: (360) 427-9436 ● FAX: (360) 427-4396

## ADDENDUM 2

### Parking Area Grading and Gravel Surfacing MCD Contract #2026-07

**To:** Prospective Bidders for the MCD Contract #2026-07

**From:** Andy Sorter, Mason Conservation District Engineer

**Date:** April 27, 2026

**SUBJECT:** Addendum 2 to Bid Solicitation, "Parking Area Grading and Gravel Surfacing,"  
MCD Contract #2026-07

This Addendum modifies the bid solicitation for the project, which is scheduled for bid opening April 30, 2026 at 10:00 a.m.

All bidders are asked to review this addendum, consider it in preparation of their bids, and acknowledge this consideration by initialing the line on the bid proposal form for Addendum 2.

This Addendum will answer questions from prospective bidders that were received prior to the deadline to submit questions about this project.

**The following are questions from prospective bidders submitted to Mason Conservation District prior to the deadline to submit questions about this project and their answers.**

**Question:** "Your not to exceed price for the budget is just enough to only buy and truck in the crushed rock fyi."

**Answer:** Mason Conservation District agreed that the original scope of work requiring two (2), 3-inch lifts of 3/4-inch minus crushed rock would likely not fit within the project budget. Addendum 1 addressed this and reduced the number of 3-inch lifts of 3/4-inch minus crushed rock down to one (1), 3-inch lift of 3/4-inch minus crushed rock. This change reduced the estimated total cubic yards of 3/4-inch minus crushed rock needed for this project from 228 cubic yards down to 114 cubic yards.

Thank you for your time and consideration,

Andy Sorter  
[asorter@masoncd.org](mailto:asorter@masoncd.org)  
360 968-0736